

N.F. RAILWAY

OFFICE OF THE
General Manager(M)
Maligaon: Guwahati - 781011

No.M-218/MISC/PMP

Date : May 12, 2008

M/s. Shree Shyam Bearings Pvt. Ltd.
207, 2nd Floor, 138. B.R.B.Basu Road
(Canning Street)
Kolkata- 700 001
Fax No. 033-22426708

Dear Sir,

Sub: Presentation and live demonstration of Elide Fire- Fire Extinguishing Ball.

Ref: Your L/No. SSBPL/EFB/NFR/08-09 dtd. 25.04.08.

A Live Demonstration of Elide Fire – Fire Extinguishing Ball was conducted by you on 08.05.08 at Coaching Depot, Guwahati.

The above type of Fire extinguisher appears to be nontoxic to the environment and there is no need to get close to the fire. However, it appears that it is unsuitable in large fuel fires.

The demonstration was found to be satisfactory.

Thanking you,


12-5-08
(B. LAKRA)
Dy.CME/Planning
For General Manager(M)/MLG